



OIL AND NATURAL GAS CORPORATION LIMITED
Fire Services, Western Onshore Basin
Makarpura Road, Vadodara-390009
Phone Nos. 0265-2603606/ 2603612

No. BDA/FS/NOC/2021

Date: 29.06.2021

NO OBJECTION CERTIFICATE

This is to certified that the school of **Kendriya Vidyalaya No.4, ONGC Vadodara** having Ground floor School located at ONGC Campus, Makarpura Road, ONGC, Vadodara. It has been provided for the required fire protection and inspected towards operation of fire extinguishers, fire alarm system and smoke detectors at School on 29.06.2021. All equipment are in working condition and well maintained and fire risks observed very low category and evacuation in case of emergency cannot be a problem because all exits are at ground floor.

In view of the above the NOC is being issued to the above school as it is protected by following fire fighting appliances.

- **Fire Extinguishers:**
- 4.5 Kg Capacity Co2 Fire Extinguishers 05 nos.
- 10 Kg Capacity DCP(ABC Type) Fire Extinguishers 04 nos
- 02 Kg Capacity DCP(ABC Type) Fire Extinguishers 06 nos.
- 02 Kg Capacity Co2 Fire Extinguishers 04 nos.
- Fire Buckets with stand 01 nos.

- **Fire Alarm System**
- MCP 09 nos.
- Hooters 09 nos.
- **Smoke Detectors** 20 nos.

All above fire equipment installed tested, maintained in working order and same will be checked quarterly basis by the fire services.

Received on
30.6.21

Viraj meherana
TUNGE

Office for all
records, L&B/
CRSE/VMC/fire
affiliation

30/6.

(Sr. Fire Officer)
For I/C – Fire Services
ONGC, Vadodara